

MINUTES OF PRE BID MEETING FOR ELECTRIFICATION COMPONENT

BETWEEN

NEPAL ELECTRICITY AUTHORITY, BIDDERS,

POWER GRID CORPORATION OF INDIA LIMITED

AT NEA OFFICE, RATNAPARK, KATHMANDU ON 2ND AUGUST' 2019

SUBJECT : Pre Bid meeting for Electrification Component between Nepal Electricity Authority (NEA), the Employer, Bidders and Power Grid Corporation of India Limited (POWERGRID), the Consultant for Reconstruction and Improvement of Electricity in Earthquake Affected Districts of Rasuwa & Nuwakot Project.

PRESENT: For the Employer

Mr. Prakash Raut

Project Manager 

Mr. Sushil Pudasaini

Account Officer 

For the Bidders

Mr. Hem Raj Luitel

A2Z Infra Engineering Limited

Mr. Vikram Singh

Navadurga Julpa

Mr. Wang Mimi

TBEA Deyang Cable Co.Ltd

Mr. Ananda Gauchan


Otard

Mr. Aaditya Agrawal


Singhi Infrapower Products

For the Consultant


Mr. Atul Kumar Agrawal

Project Manager, POWERGRID 

Mr. Sanjay Kumar Rai

Civil Expert, POWERGRID 

Mr. Deepak Subedi

Asst. Manager, Jade Consult 

Record of Discussion:

1. The Bidders were informed in detail about the project background and the work scope of the project.

2. The Bidders were informed about the Evaluation & Qualification Criteria as mentioned in the Tender Documents.
3. The Bidders were informed about the bidding forms to be used for the bid purpose.
4. The Bidders raised query if the same bidding forms of the bid document are to be used. It was clarified that the Bid Forms provided in the Bid Document are to be strictly followed and no any deviation will be permitted.
5. The Bidders raised the query if the drawings for the buildings of the substation are provided in the Bid Document. It was clarified that indicative plan drawings for the buildings have been attached in the bid document.
6. The Bidders raised the query regarding the location of the project components. The same was clarified by providing the locations.
7. The bidders raised the query regarding the feeding points for Kalikasthan and Ratmate Substation. It was clarified that Kalikasthan will be fed from Trishuli 3B Hub Substation and Ratmate will be fed by tapping from existing 33kV Devighat – Galchi Transmission Line.
8. The Bidders raised query about the accessibility for the substation sites. It was clarified that both the substation site are easily accessible from the nearby Highway.
9. The Bidders were informed about the Type Test Requirement of the Major Electrical Equipment. It was clarified that in case the type test report is not available as per TS for any item, the type test shall be conducted at no extra to NEA.
10. The Bidders raised query about the storage location for the dismantled materials. It was clarified that the materials have to be stored in nearby NEA office (Dhunche or Kalikasthan) whichever is convenient.
11. The Bidders were requested to send any other query/ clarifications they may need (if any) on the Bid Documents by 13th August 2019 in written form via email to the Project Office.

Signature on behalf of

NEA

BIDDERS

POWERGRID

Jade Consult

Handwritten signature and date: 13/8/19

Handwritten signature and date: 13/8/19

Handwritten signature