

Lekhnath Damauli 220 kV Transmission Line Project

Package B: Substations

BMZ201667773/KfW508598

List of Queries and Clarifications

Document No B_1

September 28, 2022

No	Reference	Query	Clarification
1	Section IV Conformity of the Facility Requirements Page 119 of 146	Requirement currently reads: <i>GIS manufacturer experience in foreign countries shall be more than 15 years. Evidence shall be provided.</i> Proposed modification: GIS manufacturer with 10 years of manufacturing experience and shall provide evidence of supply in foreign country.	Stated requirement shall be maintained.
2	Section IV Conformity of the Facility Requirements Page 119 of 146	Requirement currently reads: <i>The type test certificates shall not be older than 10 years and shall be issued from an independent institute.</i> Proposed modification: The type test certificates shall not be older than 15 years and shall be issued from an independent institute. and type test reports of parent company / collaborator are acceptable provided same design and process by which parent company / collaborator has manufactured the equipment, has been followed by the manufacturer.	Stated requirement shall be maintained.

№	Reference	Query	Clarification