

Nepal Electricity Authority
Transmission Directorate
Grid Operation Department
Supply, Delivery, Shifting, Installation, Testing and Commissioning of Power Transformers at Various Substations

Contract Identification No. (IFB No.) : GOD/2079/080-04
Clarification Response -01

SN	Bidding Document/Section/ Clause	Bidder's Clarification Request	NEA Response
1	Vol-I Section 9 Contract Forms Appendix 2 : Price Adjustmet	Following the clause 1.2 of Appendix 2: Price Adjustment, shows "Also, since advance payment will be made to the Contractor, price adjustment will not be allowed on this amount and accordingly, price adjustment will not be allowed on this amount and accordingly, price adjustment shall be permitted for 90% (if 10% advance is taken) cost of the Material only." As the advance payment (10%) will be deducted from the interim settlement, so the range of price adjustment should be 100% of the adjustable part.	It shall be as per the Bidding Document
2	Vol-III of III Price Schedules Price Schedule No 3: Design Services And Section 8 Special Conditions of Contract	In the Price Schedule No 3: Design Services shows that "The scope of the Contract covers the detail design in Not applicable", and Clause 20 in Section 8 Special Conditions of Contract shows "The Contractor shall provide detail condition and specification or parameters taken under consideration for design/ redesign (wherever applicable) of the substation and its cost shall be deemed to be included in the contract price." Please clarify which one is correct?	It shall be as per the Bidding Document (Price Schedule no 3 : The scope of the Contract covers the detail design as well. The price of the detail design is deemed to have been covered in the prices of the other schedules)
3	Vol II Section - I Part-08 Specification of 12KV Switchgear Panel	The scope of work for some substations include the supply, installation and testing of switchgear. Please confirm the switchgear is for the whole substation or the transformer which will be shifted.	They are for the transformers which will be shifted and installed.
4	Vol II Section - I Part-08 Specification of 12KV Switchgear Panel	The main equipment has been marked the short listed Manufacturers in General Technical Specification, please confirm that the contractor must select the one of them or other Manufacturers which has equal quality level.	It shall be as per the Bidding Document
5	Vol - I Part III Conditions of contract and contract Forms, Section 7, General Conditions of Contract 42.8 Payment upon Termination if the contract is terminated because of fundamental breach of Contract or for any other fault by the contractor, the performance security shall be forfeited by the Employer. In such case, amount to complete the remaining works as per the contract shall be recovered from the Contractor as Government dues.	Sub-clause 42.8 [Payment upon termination] only provides for payment upon termination caused by a fundamental breach of Contract by the Contractor. However, the Contractor's entitlement to payment upon termination caused by a fundamental breach of contract by the Employer and termination for "Employer's convenience " are not provided in either GCC or SCC. Please clarify	It shall be as per the Bidding Document

(Signature)
(Signature)