

Supply, Installation, Testing and Commissioning of Parwanipur-Pokhariya 132 kV Transmission Line

Invitation for Bids No.: PMD/PTDSSP/HPP/2080/81-01

OCB No.: PMD/PTDSSP/HPP/2080/81-01

Bidder's Query	NEA's Response
Please clarify whether the OLTE in Parwanipur substation is required to be supplied by the bidders.	The communications equipment at both ends, Parwanipur and Pokhariya, is in the scope of other projects. However, at Parwanipur Substation, though there is the communications equipment, the contractor shall provide necessary minor cards, equipment, etc. if required for successful operations of communications between Pokhariya and Parwanipur without any extra cost implication to NEA.

